

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM
LISTING SERVICE



LISTING No. 2280-1245:100

Page 1 of 1

CATEGORY: Coating Material

LISTEE: Coustic-Glo International, 7111 Ohms Ln., Minneapolis MN 55435
Contact: Gary E Smith (952) 835-1338 Fax (952) 835-1395*

DESIGN: COUSTIC COAT Formulas 0 through 6. Fire-retardant chemical coating for interior ceiling panels.
Refer to listee's data sheet for detailed product description and operational considerations.

RATING:	FLAME SPREAD	SMOKE DENSITY
USG Quitone Coustic-coat No. 0 ¹	5	5
USG Quitone Coustic-coat No. 4 ²	10	5
USG Auditone Coustic-coat No. 0 ¹	10	5
USG Auditone Coustic-coat No. 4 ²	10	10

¹ Sprayed applied at a rate of 200 sq. ft. per gallon

² Sprayed applied at a rate of 150 sq. ft. per gallon.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, product label and CSFM label.

APPROVAL: Listed as a coating material for application to interior ceiling surfaces to reduce flame spread when the coatings are applied at the rates specified.

*Rev. 06--16-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **MAY 19, 2008**

*Listing Expires **June 30, 2009***

Authorized By: **BEN HO, Chief**
Fire Engineering Division